



Certificate of Fire Extinguisher

This certificate is proudly presented to

M/s. JAIN INTERNATIONAL PUBLIC SCHOOL

AT.PO.- CHANVAI,

DIST.- VALSAD .


We have carried out Maintenance / Servicing / Repairs /
Reconditioning / Refilling Hy. Testing and Installation of
Fire Extinguisher, Fire Fighting Systems As per IS : 2190

We further certify that all are in good working and operational
condition as per Invoice No. TS/23-24/0563 Dated 12-Feb-2024

Certificate No.: 563

Refilling Date : 12-Feb-2024

Due Date : 11-Feb-2025



ABC Type : 04 Kg.- 02 Nos.

A

ABC Type : 06 Kg.- 03 Nos.

B

CO2 Type : 4.5 Kg.- 01 No.

C

D

E

F



Managed by : Shri Manaji Jain Charitable Trust, Valodol

JAIN INTERNATIONAL PUBLIC SCHOOL

શ્રી મનાજી જાઈ શ્રેણીયોલે ટ્રસ્ટ વાલોલ

ફાયર સેફ્ટી અંગેનું સ્વપ્રમાણિત સર્ટિફિકેટ

ગુજરાત ફાયર સેફ્ટી પ્રિવેનશન એન્ડ લાઈટ સેફ્ટી મેજર્સ એક્ટ- ૨૦૧૩ એન્ડ રૂલ્સ-૨૦૧૪ તેમજ સુધારાવિધાયક ૨૦૨૧માં કરવામાં આવેલ જોગવાઈઓ અંતર્ગત તથા શહેરી ગૃહ નિર્માણ વિભાગના નોટીફિકેશનનું જીએચ /V/9 of 2021/AGN-102021-100-1-1 તા ૨૨-૧-૨૦૨૧ મુજબ અમારી શાળાનાં બિલ્ડીંગનું નામ જૈન ઇન્ટરનેશનલ પબ્લીક સ્કૂલ વલસાડ સ્થાપના વર્ષ ૨૦૧૩ જે ભાડાના બિલ્ડીંગમાં ૨૦૧૮માં લઈ ગયા જેનું બાંધકામ ફક્ત ગ્રાઉન્ડ ફ્લોરનું કરેલ છે.જેની ઉચાઈ 4m સુધીની છે.નેશનલ બિલ્ડીંગ કોડ ઓફ ઇન્ડિયા પાર્ટ-૪ ની ગાઈડ લાઈન તેમજ ગુજરાત ફાયર પ્રિવેનશન એન્ડ લાઈટ મેજર્સ એક્ટ તથા ૨૦૨૧ માં રજુ કરવામાં આવેલ સુધાર વિષયક જોગવાઈઓ મુજબ અમારી ઉપરોક્ત શાળા બિલ્ડીંગ આ સાથે જણાવેલ સાધનો ફિટ કરવામાં આવેલ છે.જેની ખરાઈનું સ્વપ્રમાણિત સર્ટિફિકેટ છે

Have Portable fire extinguishers(as per Is:15683)been provided Yes() No ()

Type Of F.E	Capacity & Quantity			Cylinder	Total
	4Kg	4.5Kg	6Kg		
Co2(Kg)		1		1	4.5x1 = 4.5
ABC (Kg)	2		3	2	4x2 = 8
				3	6x3 = 18

Photo Auto Glow Signages	Fire Fighting Equipment	Emergency Routemark	Way To Staircase	Emergency Hazzards	Fire Fight Pump	Water Tank 2000 Litres	Own Water Bore
	Yes (✓) No ()	Yes (✓) No ()	Yes () No ()	Yes (✓) No ()	Yes () No (✓)	Yes (✓) No ()	Yes (✓) No ()

JAIN INTERNATIONAL PUBLIC SCHOOL

Authorised Signatory