



TC - 5945

**POLLUCON LABORATORIES PVT. LTD.****TEST REPORT**

QF/7.8/01

ULR: TC594524000004179F

Page: 1 of 1

Customer's Name and Address :

**JAIN INTERNATIONAL PUBLIC SCHOOL  
OPP. PATHARI DATT TEMPLE, DHARAMPUR - CHANVAI -  
ATUL ROAD, CHANVAI, VALSAD 396001, GUJARAT,  
INDIA.**

Test Report No.: **PLPL/24/04/01/0032**Issue Date : **10/04/2024**Customer's Ref.: **Verbal**

Description of Sample : **Water Sample\*** Quantity/No. of Samples : **01 Ltr/01**  
 Date of Sampling : **01/04/2024** Protocol (Purpose) : **IS 10500 : 2012**  
 Sampling by : **Pollucon Laboratories Pvt. Ltd.**  
 Sample Receipt Date : **01/04/2024** Sampling Procedure : **IS: 3025 (Part-I)**  
 Packing/ Seal : **Sealed** Lab ID : **PLPL/24/04/01/0032**  
 Date of Starting of Test : **01/04/2024** Date of Completion : **10/04/2024**

**RESULT TABLE**

SR. NO.	PARAMETERS	UNIT	RESULT	LIMIT AS PER IS 10500:2012	TEST METHOD
1	Odour	--	Agreeable	Agreeable	IS 3025 (Part 5)
2	Colour	Hazen	3	Max. 5	IS 3025 (Part 4)
3	Taste	--	Agreeable	Agreeable	IS 3025 (Part 7)
4	pH Value	--	7.34	6.5 - 8.5	IS 3025 (Part 11)
5	Turbidity	NTU	0.06	Max. 1	IS 3025 (Part 10)
6	Total Dissolved Solids	mg/L	21	Max. 500	IS 3025 (Part 16)
7	Total Hardness as CaCO <sub>3</sub>	mg/L	6	Max. 200	IS 3025 (Part 21)
8	Chloride as Cl	mg/L	3.99	Max. 250	IS 3025 (Part 32)
9	Fluoride	mg/L	Not Detected	Max 1.0	APHA (23 <sup>rd</sup> Edition) 4500 F D
10	Iron	mg/L	Not Detected	Max 0.3	APHA (23 <sup>rd</sup> Edition) 3500 Fe B
11	Colliform	/100ml	Absent	Absent	APHA (23 <sup>rd</sup> Edition) 9221 D
12	Escherichia coli	/100ml	Absent	Absent	IS 1622 2019

Note : Sample found conforming as per IS 10500:2012 standard for the tested parameters.  
 Detection limit: Fluoride, Iron: < 0.05mg/L

\* : Detail given by customer.

**H.T. Shah**  
 Lab Manager

**Sweety Jain**  
 Microbiologist

**Dr. Arun Bajpai**  
 Lab Manager(Q)

Note: This report is subject to terms & conditions mentioned overleaf.